

Flashclad extruded aluminium  
2 Part Jamb

3mm gap between bottom edge  
of the cladding and the top of the  
Flashclad Sill

Flashclad extruded aluminium  
Sill with End Cap (shown dashed)

NOTE:  
Sill provides full joinery support  
(wanz bar not required)

Flashclad extruded aluminium  
Sill Bead

Bevelbord extruded aluminium  
cladding installed by Flashclad  
Nationwide Distributor Network

NOTE:  
Fixing into studs at maximum  
600mm centres.  
Type 17 stainless steel 65mm  
roofing screws.

20mm H3.1 vertical cavity batten  
with separation layer over

Flashclad aluminium Mitre  
Soaker supplied by Flashclad  
installed by Builder

10mm gap

H3.1 packer supplied and  
installed by Flashclad

H17 type SS screw at 600 crs  
with minimum 65mm frame  
embedment

Flashclad Back Plate  
(shown dashed)

Building wrap or Rigid Air  
Barrier installed as per  
manufacturers specification

25mm from the outside face of the  
framing (for building wrap detailing)  
or 25mm from the outside face of the  
Rigid Air Barrier to the back of the  
aluminium window or door frame

NOTE:  
Aluminium joinery installed with  
flashing tape and air seal over  
PEF backing rod as per  
NZBC E2/AS1