

20mm H3.1 vertical cavity batten  
with separation layer over

Horizontally fixed Dualbord extruded  
aluminium cladding installed by  
Flashclad Nationwide Distributor Network

NOTE:  
Fixing into studs at maximum  
600mm centres.  
Type 17 stainless steel 65mm  
roofing screws.

Building wrap or Rigid Air  
Barrier installed as per  
manufacturers specification  
cut for pipe penetration

NOTE:  
All penetration to have covers  
installed by relevant trades

Square of flexible flashing tape  
to a minimum of 100mm  
around outside of pipe, ensure  
seal with pipe bandage

25mm minimum wide flexible  
flashing tape bandage all  
round pipe

Pipe to have minimum 5° fall  
to outside

